

Declaration of Performance

Version: F

1. Unique identification code of the product

F-C2

Valid for all subtypes: F-C2...VA; F-C2...OF

2. Type

Systemair Cartridge Fire Damper F-C2

3. Intended use of the construction product

Fire closure for HVAC ductworks for the compartmentization

4. Name, registered trade name and contact address of the manufacturer

Systemair Production a.s.

Hlavná 371,

90043 Kalinkovo, Slovakia

5. Where applicable, name and contact address of the authorized representative

6. System of assessment and verification of constancy of performance of the construction product

System 1

7. Harmonized product standard, test standard, classification standard

EN 15 650:2010

8. Identification number of the notified body

1396

Name and address of the notified person:

FIRES s.r.o.,

Osloboditeľov 282,



















059 35 Batizovce, Slovakia








Notified person performed in system 1 the determination of the product type based on type testing (including sampling) and descriptive documentation of the production initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control and issued certificate of constancy of performance:











1396 - CPR - 0183
















9. Declared performance, Installations:

 Wet	F-C2	El 60 ($v_e i \leftrightarrow o$) S	≥ 100 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	 360°
		El 90 ($v_e i \leftrightarrow o$) S	≥ 120 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	
		El 120 ($v_e i \leftrightarrow o$) S	≥ 125 mm ≥ 100 mm (DN140 ... DN200) 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	
		El 120 ($h_o i \leftrightarrow o$) S	≥ 150 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	
 Dry	F-C2	El 60 ($v_e - i \leftrightarrow o$) S	≥ 100 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	 360°
		El 90 ($v_e - i \leftrightarrow o$) S	≥ 100 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	
		El 120 ($v_e i \leftrightarrow o$) S	≥ 150 mm ≥ 125 mm (DN 80 ... DN125) 	≥ 150 mm ≥ 125 mm (DN80 ... DN125) $(\geq 500 \text{ kg/m}^3)$ 	
 Soft	F-C2	El 60 ($v_e i \leftrightarrow o$) S	≥ 100 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	 360°
		El 90 ($v_e i \leftrightarrow o$) S	≥ 100 mm 	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$ 	
		El 120 ($v_e i \leftrightarrow o$) S	≥ 150 mm 	≥ 150 mm $(\geq 500 \text{ kg/m}^3)$ 	

 Wet	F-C2...VA	El 60 ($v_e i \leftrightarrow o$) S	a)  ≥ 100 mm	b)  ≥ 100 mm (≥ 500 kg/m ³)	 360°
		w)  ≥ 120 mm			
		El 90 ($v_e i \leftrightarrow o$) S	a)  ≥ 125 mm ≥ 100 mm (DN160 ... DN200)	b) 	
		El 120 ($v_e i \leftrightarrow o$) S	a)  ≥ 150 mm		
		El 120 ($h_o i \leftrightarrow o$) S	c)  ≥ 100 mm ≥ 600 kg/m ³		

 Dry	F-C2...VA	El 60 ($v_e - i \leftrightarrow o$) S	a)  ≥ 100 mm	b)  ≥ 100 mm (≥ 500 kg/m ³)	 360°
		El 90 ($v_e - i \leftrightarrow o$) S			
		El 120 ($v_e i \leftrightarrow o$) S	a)  ≥ 150 mm ≥ 125 mm (DN80 ... DN125)	b)  ≥ 150 mm ≥ 125 mm (DN80 ... DN125) (≥ 500 kg/m ³)	

 Soft	F-C2...VA	El 60 ($v_e i \leftrightarrow o$) S	a)  ≥ 100 mm	b)  ≥ 100 mm (≥ 500 kg/m ³)	 360°
		El 90 ($v_e i \leftrightarrow o$) S			
		El 120 ($v_e i \leftrightarrow o$) S	a)  ≥ 150 mm	b)  ≥ 150 mm (≥ 500 kg/m ³)	

 Wet	F-C2...OF	El 60 ($v_e i \leftrightarrow o$) S	≥ 100 mm  ≥ 120 mm 	 ≥ 100 mm $(\geq 500 \text{ kg/m}^3)$	 360°
		El 90 ($v_e i \leftrightarrow o$) S	 ≥ 125 mm ≥ 100 mm (DN160 ... DN200)		
		El 120 ($v_e i \leftrightarrow o$) S	 ≥ 150 mm	≥ 100 mm $(\geq 500 \text{ kg/m}^3)$	
		El 120 ($h_o i \leftrightarrow o$) S	 ≥ 100 mm $\geq 600 \text{ kg/m}^3$		
 Dry	F-C2...OF	El 60 ($v_e - i \leftrightarrow o$) S	 ≥ 100 mm	 ≥ 100 mm $(\geq 500 \text{ kg/m}^3)$	 360°
		El 120 ($v_e i \leftrightarrow o$) S	 ≥ 150 mm ≥ 125 mm (DN100 ... DN125)	 ≥ 150 mm ≥ 125 mm (DN100 ... DN125) $(\geq 500 \text{ kg/m}^3)$	
 Soft	F-C2...OF	El 60 ($v_e i \leftrightarrow o$) S	 ≥ 100 mm	 ≥ 100 mm $(\geq 500 \text{ kg/m}^3)$	 360°
		El 120 ($v_e i \leftrightarrow o$) S	 ≥ 150 mm	 ≥ 150 mm $(\geq 500 \text{ kg/m}^3)$	

Note:

Installations of subtype **F-C2...OF** were tested without connected duct, with natural convection.

Legend:

1. Wet - Wet Installation, Using Plaster/Mortar/Concrete Filling

2. Dry - Dry Installation, Using Mineral Wool and Coverplates

3. Soft - Soft Installation, Using Mineral Wool filing

a) - Flexible (plasterboard) wall

w) - Timber stud wall

b) - Concrete/masonry/cellular concrete (rigid) wall

c) - Concrete/cellular concrete (rigid) floor/ceiling

v_e - Vertical supporting construction (wall)

h_o - Horizontal supporting construction (floor/ceiling)

Assessment of F-C2 and subtypes F-C2...VA; F-C2 ...OF

Property	Test regulation	Classification standard	Technical specification for assessment	Performance expressed	Evaluation
Nominal activation /Sensing element conditions /sensitivity	ISO 10294-4	/	EN 15650 4.2.1.2 4.2.1.2.2 4.2.1.2.3	- load-bearing capacity in accordance with ISO 10294-4, 4.2; - response temperature in accordance with ISO 10294-4, 4.2;	Satisfied
Response delay (response time)	EN 1366-2	/	EN 15650 4.2.1.3	closure time within time period of 2 minutes	Satisfied
Operational reliability	EN 1366-2	/	EN 15650 4.3.1 a)	50 cycles	Satisfied
Fire resistance - integrity - insulation - smoke leakage - mechanical stability	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.1.1, a), cl. 4.1.1 b), cl. 4.1.1 c), cl. 4.1.1 a),	See installation Table 9.	Satisfied
Fire resistance maintenance of cross-section	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.4.1 a)	See installation Table 9.	Satisfied
Durability of response delay	ISO 10294-4	/	EN 15650 4.3.3.1	Durability of response delay (by tested temperature response and load-bearing capacity) is preserved.	Satisfied
Durability of operational reliability	EN 15650 Annex C	/	EN 15650 4.3.3.2	NPD (no performance determined)	/

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer by:



Kalinkovo, October 16, 2025

Ing. Maroš Chlebo, Managing Director